

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 2200-0174:001 Page 1 of 1

CATEGORY: Ceiling Suspension System/Panels

LISTEE: United Plastics, 513 Independent Rd., Oakland CA 94621  
Contact: \*David Baker (510) 569-6700

DESIGN: Model CEILUMNE Clear or white polyvinyl chloride plastic single and double sheets to form 2' x 2' to 2' x 4' nominal translucent ceiling panels. Type I, single sheet; Type II, nested or welded sheets; Type III and IV, nested or welded double sheets with a laminated top sheet; Type V, top and bottom sheet mechanically laminated to a flexible vinyl center sheet. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	TYPE	I	II	III	IV	V
	Flame Spread	20	25	35	20	25
	Smoke Developed	150	350	400	350	350

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Cartons imprinted "ULC" followed by Type number; top flange of panels stamped or embossed "U" followed by a suffix letter and number.

APPROVAL: Listed as a translucent ceiling panel having a Class I or II rating.

NOTE: Formerly 2180-0174:001

\*Rev. 05-14-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 14, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager